

Biddle Test	Exposure to electrical shock	Procedures, training	N	2	2	2	2	16								
Biddle Test (climb above station I)	Falls to lower level	Use of approved ladder	N	1	2	3	2	12								
Secure Station I and II doors	Becoming caught in or compressed by equipment such as pinch point at switch	Using appropriate sized shims	N	2	2	2	2	16								
Remove LOTO	Exposure to electrical shock	Procedures, training, permits, communication with MCR	N	2	2	1	2	8								

--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

*Risk:	0 to 20	21 to 40	41-60	61 to 80	81 or greater
	Negligible	Acceptable	Moderate	Substantial	Intolerable