

*If you are using a printed copy of this procedure, and not the on-screen version, then you **MUST** make sure the dates at the bottom of the printed copy and the on-screen version match. The on-screen version of the Collider-Accelerator Department Procedure is the Official Version. Hard copies of all signed, official, C-A Operating Procedures are available by contacting the **ESSHQ Procedures Coordinator, Bldg. 911A***

C-A OPERATIONS PROCEDURES MANUAL

ATTACHMENT

3.5.a List of Alarms Requiring Immediate Main Control Room Response

C-A OPM Procedures in which this Attachment is used.		
3.5		

Hand Processed Changes

<u>HPC No.</u>	<u>Date</u>	<u>Page Nos.</u>	<u>Initials</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Approved: _____ *Signature on File* _____
 Collider-Accelerator Department Chairman Date

W. Anderson

List of Alarms Requiring Immediate Main Control Room Response

Alarm	Action Required	Notifications
STAR – High Level Gas	“Support One” Verifies all AUTO functions operate, i.e. AUTO OFF. IR access to investigate source	“Support One” and STAR Person in Charge
STAR – Substation Ground Fault	Find fault within 8 hours. Notify Department Chief E.E. after 8 hours	“Support One” and C-A Chief E.E.
STAR – Emergency OFF Activated	“Support One” verifies all AUTO functions operate. IR access to investigate source	“Support One” and STAR Person in Charge
STAR – Water Leak	“Support One” verifies AUTO functions operate	“Support One” and STAR Person in Charge
Phenix – IR High Level Gas	“Support One” verifies AUTO functions operate. Ventilate IR. IR access to investigate source	“Support One” and Phenix Person in Charge
Phenix – IR Low Level Gas	“Support One” ventilates IR manually IR access to investigate source	“Support One” and Phenix Person in Charge
Phenix – Gas Mixing House (GMH) High Level Gas	“Support One” verifies AUTO functions operate. GMH access to assess fault.	“Support One” and Phenix Person in Charge
Phenix – Gas Mixing House Low Level Gas	“Support One” ventilates GMH	“Support One” and Phenix Person in Charge
Phenix – Substation Ground Fault	Find Fault within 8 hours Notify Department Chief E.E. after 8 hours	“Support One” and C-A Chief E.E.
Phenix – Emergency OFF Activated	“Support One” verifies AUTO functions operate. Assist Phenix to determine source of fault	“Support One” and Phenix Person in Charge
Phenix – Water Leak	Access to IR for major leak	“Support One” and Phenix Person in Charge