

*If you are using a printed copy of this procedure, and not the on-screen version, then you **MUST** make sure the dates at the bottom of the printed copy and the on-screen version match. The on-screen version of the Collider-Accelerator Department Procedure is the Official Version. Hard copies of all signed, official, C-A Operating Procedures are available by contacting the ESSHQ Procedures Coordinator, Bldg. 911A*

C-A OPERATIONS PROCEDURES MANUAL

7.1.30 Insulating Vacuum System #2 for Absorber Beds A and B

Text Pages 2 through 6

Hand Processed Changes

<u>HPC No.</u>	<u>Date</u>	<u>Page Nos.</u>	<u>Initials</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Approved: _____ *Signature on File* _____
Collider-Accelerator Department Chairman Date

D. Lederle

7.1.30 Insulating Vacuum System #2 for Absorber Beds A and B

1. Purpose

This procedure provides instructions for the operation of vacuum skid 2 for the insulating vacuum of absorber beds A and B of the RHIC 25 kW helium refrigerator. Vacuum skid 2 consists of two sets of Kinney fore pumps, 2-E515 and 2-E565, two sets of Varian diffusion pumps, 2-E511 and 2-E561, interconnecting piping, valves, instrumentation and control. Under normal operation, 2-E511 and 2-E515 are dedicated for Absorber B. 2-E561 and 2-E565 are dedicated for Absorber A.

2. Responsibilities

- 2.1 The Shift Supervisor or an operator designated by the Shift Supervisor is responsible for conducting the procedure and providing documentation in the Cryogenic Control Room Logbook.
- 2.2 Should a problem arise during the completion of this procedure, the Shift Supervisor shall contact the Technical Supervisor for instructions before continuing.

3. Prerequisites

- 3.1 The Operator shall become familiar with the Vacuum System #1, #2 & #3 P&I D drawing 3A995011.
- 3.2 The diffusion pumps are mounted on the 4-inch penetration on the absorber vacuum vessels. The absorbers, the control panel and the entire vacuum skid 2 are located on the lower level of the refrigerator building. The Operator shall familiarize themselves with the locations of the hardware.
- 3.3 The control panel consists of control switches, vacuum gages and the status of the control valves, the slide valves, the fore pumps and the diffusion pumps. The Operator shall familiarize themselves with the function of the control panel.
- 3.4 The Operator shall become familiar with the operation of the Kinney KC-15 compound vacuum pump and the Varian diffusion pump.
- 3.5 All personnel working on any electrical system or equipment in the C-AD shall be familiar with BNL [SBMS Electrical Safety](#), BNL [SBMS Lockout/Tagout \(LO/TO\)](#), [C-A-OPM 1.5, "Electrical Safety Implementation Plan"](#), [C-A-OPM 1.5.3 "Procedure to Open or Close Breakers and Switches and Connecting/Disconnecting Plugs"](#), [C-A-OPM 2.36, "Lockout/Tagout for Control of Hazardous Energy"](#). C-AD will provide on-site/work specific training to individuals in the electrical safety aspects of their job functions and assignments.

4. Precautions

- 4.1 General safety precautions on the operation of cryogenic system.
- 4.2 The bottom of the diffusion pump will be very hot. The operator shall not touch it.
- 4.3 The Diffusion Pumps have high temperature alarms which are initiated by the following instruments:
 - Diffusion Pump 2-E511 High Temperature 2-TSH511
 - Diffusion Pump 2-E561 High Temperature 2-TSH561
- 4.4 Hearing protection shall be worn when the compressors are in operation.
- 4.5 Approved eye protection and safety shoes shall be worn at all times.
- 4.6 All personnel entering the refrigeration wing of 1005R must have personal ODH monitor and carry an emergency escape pack, if there is liquid helium in the pots.

5. Procedure

5.1 Check the Oil

- _____ [1] Check the oil level from the dip stick of the diffusion pumps and sight glass of the fore pumps.
- _____ [2] If level is too low, report to the Supervisor for adding oil. Record in logbook.
- _____ [3] If oil is milky, report to the Supervisor for changing pump oil. Record in logbook.

5.2 Service Utilities

- _____ [1] Open the two (2) water inlet valves 2-W528M and 2-W578M and the two (2) outlet valves 2-W527 and 2-W577M to cool the two baffles, 2-E531 and 2-E581, and the two diffusion pumps, 2-E511 and 2-E561. Adjust flow rates to 15 gallons per hour for both 2-FI-528W and 2-FI-578W.
- _____ [2] Check air pressure from gage located upstream of 2-A523M. Instrument air shall be between 80 and 100 psig. Open air supply valves 2-A523M, 2-A529M and 2-A579M on the skid.
- _____ [3] Supply electric power from circuit 2 of the Main Distribution Panel to motor control center MCC. The switch is located on the south wall across the walk way from vacuum skid 1 in the lower level of the refrigerator

building.

- _____ [4] Supply power to the motors of fore pumps 2-E515 and 2-E565, and to diffusion pumps 2-E561 and 2-E511 from the electric feed from the main distribution panel located on the east side on the lower level of the refrigerator building.
- _____ [5] Turn on the vacuum skid 2 circuit breakers 18, 20 and 22 on the RP-2 panel located near local instrumentation panel 2.

5.3 Operating the Vacuum Skid

5.3.1 Initial Valve Positions

- _____ [1] Open the isolation valves 2-V513M and 2-V563M for fore pumps 2-E515 and 2-E565.
- _____ [2] Crack open isolation valves 2-V508M and 2-V558M.
- _____ [3] Close the isolation valve 2-V526M.

5.3.2 Turn On the Control Switch

- _____ [1] The operation of the vacuum skid is automatic and one control switch 2-HS500 starts the adsorber B system and a second control switch 2-HS550 starts the adsorber A system. The control sources are located on the lower part of the control panel for vacuum skid 2 and each absorber can be pumped down independently.
- _____ [2] By turning on the control switch 2-HS500 for absorber B and 2-HS550 for absorber A, automatic valves 2-V509A, 2-V510A, 2-V559A, and 2-V560A will be closed and the fore pumps 2-E515 and 2-E565 will be turned on.
- _____ [3] After approximately 2 minutes time delay, the control logic will open 2-V509A and 2-V510A, for absorber B, and 2-V559A and 2-V560A, for absorber A, and start to pump down the vacuum space.
- _____ [4] During the initial roughing stage, gradually open 2-V508M and 2-V558M while listening to the sound from the fore pump to avoid overloading the pump.

- _____ [5] Check the level and condition of the pump oil on the sight glass of the fore pump
- _____ [6] If the oil becomes milky, the Operator should open the ballast valve to remove water vapor contained in the pump oil. Wait for 30 minutes and close the ballast valve.
- _____ [7] Repeat step 5 and 6 if necessary. Should the condition of the oil not improve, then the Operator shall report to the supervisor for changing pump oil.
- _____ [8] Fully open 2-V508M, for absorber B, and 2-V558M, for absorber A, when the vacuum reaches 100 Torr.
- _____ [9] When the vacuum decreases to the set point (about 2 miliTorr) of vacuum gage 2PI-501V (for adsorber B) and 2PI-551V (for adsorber A), valves 2-V509A and 2-V559A will be closed.
- _____ [10] Slide valves 2-V504A and 2-V554A will be open and the diffusion pumps will be turned on for final stage of pump down. Both slide valves can be opened or closed with toggle switches located inside the control cabinet.
- _____ [11] If the adsorber vacuum 2PI-501V and 2PI-502V for adsorber B and 2PI-552V and 2PI-551V for adsorber A, do not improve over the expected time period, the operator should report to the supervisor for suitable action.

6. **Documentation**

- 6.1 The check-off lines on the procedure are for place-keeping only. The procedure is not to be initialed or signed, it is not a record.
- 6.2 The Shift Supervisor, or designee, shall document the completion of the procedure in the Cryogenics Control Room Log.

7. **References**

- 7.1 Drawing 3A995011
- 7.2 [C-A-OPM 1.5, “Electrical Safety Implementation Plan”](#).
- 7.3 [C-A-OPM 1.5.3 “Procedure to Open or Close Breakers and Switches and Connecting/Disconnecting Plugs”](#).
- 7.4 [C-A-OPM 2.36, “Lockout/Tagout for Control of Hazardous Energy”](#).

7.5 [SBMS Electrical Safety.](#)

7.6 [SBMS Lockout/Tagout \(LOTO\).](#)

8. Attachments

None