

*If you are using a printed copy of this procedure, and not the on-screen version, then you **MUST** make sure the dates at the bottom of the printed copy and the on-screen version match. The on-screen version of the Collider-Accelerator Department Procedure is the Official Version. Hard copies of all signed, official, C-A Operating Procedures are kept on file in the C-A ESHQ Training Office, Bldg. 911A.*

C-A OPERATIONS PROCEDURES MANUAL

ATTACHMENT

8.31.b Bag Filter Maintenance

C-A OPM Procedures in which this Attachment is used.		
8.31		

Hand Processed Changes

<u>HPC No.</u>	<u>Date</u>	<u>Page Nos.</u>	<u>Initials</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Approved: _____
Signature on File
 Collider-Accelerator Department Chairman _____ Date

L. Vogt

Checklist for Bag Filter Maintenance

Job WCS #: _____

(If the step does not apply; write NA in "Check" column, or if the sequence of this checklist is altered when performed, note and initial change)

	<u>Check</u>
1. Refer to RWP #_____ for radiological conditions and controls.	_____
2. LOTO if required	_____
3. Open bypass	_____
4. Floor drains within 15 ft. are plugged	_____
5. Close isolation valves	_____
6. Relieve pressure	_____
7. Drain vessel	_____
8. Change filters	_____
9. Solid waste in plastic bag	_____
10. Seat bag in housing	_____
11. Check seal or O-ring	_____
12. Fill & Vent system	_____
13. Open Isolation valves	_____
14. Close bypass	_____
15. Leak check	_____
16. Remove LOTO if required	_____
17. Activation check and/or contamination check all items removed as indicated by H.P.	_____
18. Transfer waste water to approved drum/tank	_____

Signature: _____

Date: _____