

If you are using a printed copy of this procedure, and not the on-screen version, then you MUST make sure the dates at the bottom of the printed copy and the on-screen version match. The on-screen version of the Collider-Accelerator Department Procedure is the Official Version. Hard copies of all signed, official, C-A Operating Procedures are kept on file in the C-A ESHQ Training Office, Bldg. 911A.

C-A OPERATIONS PROCEDURES MANUAL

ATTACHMENT

8.31.d Pump Maintenance

C-A OPM Procedures in which this Attachment is used.		
8.31		

Hand Processed Changes

<u>HPC No.</u>	<u>Date</u>	<u>Page Nos.</u>	<u>Initials</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Approved: _____ *Signature on File* _____
 Collider-Accelerator Department Chairman Date

L. Vogt

Checklist for Pump Maintenance

Job WCS#: _____

(If the step does not apply; write NA in "Check" column, or if the sequence of this checklist is altered when performed, note and initial change)

	<u>Check</u>
1. Refer to RWP# _____ for radiological conditions and controls	_____
2. LOTO	_____
3. Close isolation valves	_____
4. Floor drains within 15 ft. are plugged	_____
5. Relieve pressure	_____
6. Drain pump to container	_____
7. Repair/replace as required in accordance with mfgs. Recommendations	_____
8. Solid waste in plastic bag	_____
9. Check seal/gasket	_____
10. Fill & Vent System	_____
11. Open isolation valves	_____
12. Leak check	_____
13. Remove LOTO	_____
14. Activation check and/or contamination check all items removed as indicated by H.P.	_____
15. Transfer waste water to approved drum/tank	_____

Signature: _____

Date: _____