

Collider Accelerator Support Group
Procedure A.2.0
Original Issue Date: 09/14/04
Revision 00

FES PROCEDURES AND INSTRUCTIONS

DATE: September 14, 2004

ISSUED BY: F. Kobasiuk

SUBJECT: FES Security Equipment Work Guidelines

Attached is a memorandum by 0.1. Lowenstein dated December 7, 1988. To meet the requirements of this memorandum and minimize downtime or re-testing of the "System", a FES Security Equipment Memo's Book has been prepared and is located at the CAS Watch station (Bldg 940).

This book contains a Work Guideline Memorandum for each piece of FES equipment that is wired into a security system. To perform work on this equipment, the guidelines of these memo's are to be reviewed prior to the start of work and fully complied with.

To identify the equipment as being a component of the "System", an orange Security Tag is affixed to the equipment. Further, a yellow Security Tag is attached to the key for equipment which are controlled by the Accountable Key System (Kirk Lock).

When the work being performed requires a LOTO procedure of a security system power circuit, contact the applicable Security Group Supervisor. Inform them of the intended work and request that an authorized person from their group perform a group/operation LOTO of the circuit power.

As prescribed, affix your individual LOTO to the group/operations LOTO and request assistance in verification of a power off condition. When the work is completed, inform the person who performed the group/operations LOTO and remove your LOTO.