



# Memo

date: February 18, 2004  
to: Distribution  
from: A. Piper  
subject: "Safety-Walk"

On Friday, February 13, 2004 at 13:30 hours, A "Safety-Walk" was performed focusing on testing of the E20 (warm snake) modifications to the SEM cooling system located in building 912A.

## Safety-Walk Attendees:

Arthur Piper (C-A ESHQ)  
Peter Cernigliaro (C-A ESHQ)  
John DeBoer (C-A Supervisor)  
Mark Peragine (Technician)  
Bob Edwards (Technician)  
Mike Hamilton (Technician)  
Dan Farge (E.P. Plumber)  
Joseph Stanisci (E.P. Plumber)

## Task: Initial (start-up) testing of the warm snake SEM cooling system modifications

## Positive Observations:

- C-A water systems group coordinates the efforts of multiple groups for this task
- All perimeter doors were posted indicating that this was a noise area requiring hearing protection
- Hearing protection was worn by all workers
- All workers had the required training for this task

Negative Observations:

- The extension cord used to power test equipment was not equipped with GFCI protection
- The floor drain in close proximity to the SEM system was not sealed off
- Portable heaters are utilized in this area due to the absence of a permanently installed heater

Recommended corrective actions for negative observations will be assigned and tracked to completion in the ATS family tracking system.

Distribution: Safety-Walk attendees

R. Karol

E. Lessard

D. Lowenstein