



Memo

date: May 24, 2004
to: Distribution
from: A. Piper
subject: "Safety-Walk"

On Friday, May 21, 2004 at 11:30 hours, A "Safety-Walk" was performed focusing on the modification of power supplies by the Collider-Accelerator support group.

Safety-Walk Attendees:

A. Piper (C-A ESHQ)
A. Etkin (C-A ESHQ)
W. Anderson (Supervisor)
F. Dusek (Technical Specialist)

Task: Modification of power supplies for RHIC use

Positive Observations:

- Safety glasses are worn during drilling operations
- Drills used to perform this task are double insulated
- Safety shoes were worn by the worker
- Fiberglass ladders (no wood or metal) are used for this task
- Task lighting is used when needed to perform this task

Negative Observations:

- As a result of numerous roof leaks in this building, standing water is often present on the floor. Portable GFCI protection is required for use of all power tools and task lighting in this operation. This practice was not observed during this safety walk, however the technical supervisor of this group will instruct all staff to use portable GFCI protection henceforth.

Distribution: Safety-Walk attendees
R. Karol
E. Lessard
D. Lowenstein