



Memo

date: October 9, 2007
to: Distribution
from: D. Passarello
subject: Safety Walk - Preparation for Energizing AC power to RHIC PS

On October 8, 2007, a Field Assessment of Electrical Training Program Effectiveness and a Safety Walk through of a routine electrical job was performed. The actual task was preparation for energizing AC power to RHIC power supplies. Tasks included verifying all switches were in the off position and that cabinets were locked/secured. This was performed in building 1004B.

Safety Walk Attendees:

J. Drozd (C-A Collider Electrical Power Supply Group)
G. Heppner (C-A Collider Electrical Power Supply Group)
D. Passarello (C-A ESHQ)

Positive Observations:

- Use of PPE including safety glasses, safety shoes, and appropriate clothing and gloves as specified in OPM 1.5.3
- Technicians were very knowledgeable regarding safety and technical requirements.

Negative Observations:

- Lighting very poor in area. Use of flash light was insufficient.
Recommend that permanent fluorescents fixtures be installed closer to power supplies. These fixtures need only be on when work is being performed.

Distribution: Safety Walk Attendees

D. Bruno
R. Karol
E. Lessard
D. Lowenstein