

Go To: [911-2](#) 911-4 [911-6](#) 911-8 911-F

Alarm Code 911-0
Restore 911-1

Location: B-18 House - B 913-P

Alarm Limits
Lo Temp \leq 40 F

System: B-18 Outdoor Piping-Lo Temp

- Action:
1. Verify that lo temp condition exists
 2. Check that power to heat tracing is on
 - a) If not, turn on circuit
 - b) If on, raise thermostat to energize heat trace
 3. Verify that water flow exists
 - a) If not, check if Fast Quad System is on
 - b) If Fast Quad System is off, Note 3
 4. Note 1 & 3

- Notes:
1. Record Actions Taken
 2. MCR = Main Control Room (x 4662)
 3. Call Mech Svcs from "Call In" List

[Back to Top](#)

Alarm Code 911-2
Restore 911-3

Location: B-18 House - B 913-P

Alarm Limits
Lo Flo \leq 2.5 GPM

System: B-18 Water System - Low flo

- Action:**
1. **Verify that low flow exists**
 2. **Check for obstruction, kinked or broken hose in power supply**
 - a) **Isolate if leaking, Note 1 & 3**
 3. **Check that supply and return valves in AGS ring @ B18 sleeve are open.**
 4. **Check that Fast Quad System is on**
 - a) **If off, Note 3**

- Notes:**
1. **Record Actions Taken**
 2. **MCR = Main Control Room (x 4662)**
 3. **Call Mech Svcs from "Call In" List**

[Back to Top](#)

Alarm Code 911-6
Restore 911-7

Location: B-18 House - B 913-P

Alarm Limits
Hi Temp $\geq 80^{\circ}\text{F}$

System: Building Air Conditioning - Hi Temp

- Action:**
1. **Verify Actual Temperature**
 2. **Call AGS A/C Watch during normal working hours or MMC @ x2468 (ILR# 166942)**
 3. **Call Plant Engineering Site Shift Supervisor at x4174, cell – 872-8988 or C/W desk x4284 during off hours.**
 4. **Note 2**

- Notes:**
1. **Record Actions Taken**
 2. **MCR = Main Control Room (x 4662)**

[Back to Top](#)