

Go To: [917-2](#) 917-4 [917-6](#) [917-8](#) [917-F](#)

Alarm Code 917-0
Restore 917-1

Location: H-18 House - B 913-J

Alarm Limits
Lo Temp ≤ 40 F

System: H-18 Outdoor Piping-Lo Temp

- Action:**
1. **Verify that lo temp condition exists**

 2. **Check that power to heat tracing is on**
 - a) **If not, turn on circuit**
 - b) **If on, raise thermostat to energize heat trace**

 3. **Verify that water flow exists**
 - a) **If not, check if Fast Quad System is on**
 - b) **If Fast Quad System is off, Note 3**

 4. **Note 1 & 3**

- Notes:**
1. **Record Actions Taken**
 2. **MCR = Main Control Room (x 4662)**
 3. **Call Mech Svcs from "Call In" List**

[Back to Top](#)

Alarm Code 917-2
Restore 917-3

Location: H-18 House - B 913-J

Alarm Limits
Lo Flo \leq 2.5 GPM

System: H-18 Water System - Low flo

- Action:**
1. **Verify that low flow exists**
 2. **Check for obstruction, kinked or broken hose in power supply**
 - a) **Isolate if leaking, Note 1 & 3**
 3. **Check that supply and return valves in AGS ring @ H18 sleeve are open.**
 4. **Check that Fast Quad System is on**
 - a) **If off, Note 3**

- Notes:**
1. **Record Actions Taken**
 2. **MCR = Main Control Room (x 4662)**
 3. **Call Mech Svcs from "Call In" List**

[Back to Top](#)

Alarm Code 917-6
Restore 917-7

Location: H-18 House - B 913-J

Alarm Limits
Hi Temp $\geq 80^{\circ}\text{F}$

System: Building Air Conditioning - Hi Temp

- Action:**
1. **Verify Actual Temperature**
 2. **Call AGS A/C Watch during normal working hours or MMC @ x2468 (ILR# 166942)**
 3. **Call Plant Engineering Site Shift Supervisor at x4174, cell – 872-8988 or C/W desk x4284 during off hours.**
 4. **Note 2**

- Notes:**
1. **Record Actions Taken**
 2. **MCR = Main Control Room (x 4662)**

[Back to Top](#)

Alarm Code 917-8
Restore 917-9

Location: Fan House A

Alarm Limits
Hi level

System: A.C. Condensate Receiver - Hi Level

- Action:**
1. Verify hi level condition
 2. Lift float rod on pump alternator
 3. If level remains high
 - a) Call Plant Engineering Site Shift Supervisor at x4174, cell – 872-8988 or C/W desk x4284 during off hours.
 - b) Advise MCR
 4. If level drops, Note 1 & 3 the following work day

- Notes:**
1. Record Actions Taken
 2. MCR = Main Control Room (x 4662)
 3. Call Mech Svcs from "Call In" List

[Back to Top](#)

Alarm Code 917-F
Restore 917-C

Location: Fan House A

Alarm Limits
H₂O level

System: Equipment Pit

- Action:**
1. Verify a water level exists.
 2. Check where the water is coming from
 (A/C Condensate or Steam Lines)
 2. During normal working hours contact R. Zaharatos or
 J. Benante and
 - a) Call MMC @ x2468 (PE) >>Plumber for an A/C
 condensate leak or a Steam Fitter for a steam leak.
 - b) Call Plant Engineering Site Shift Supervisor at x4174,
 cell – 872-8988 or C/W desk x4284 during off hours.
 - c) Advise MCR

[Back to Top](#)