

Go To: 948-2 948-4 [948-6](#) [948-8](#) 948-F

Alarm Code 948-2
Restore 948-3

Location: **Building 928/929 - AGS RF/MG Buildings**

System: **MG Rectifier System - Expansion Tank Low Level**

- Action:**
- 1. Check for water leak in the system, possible leak at the mechanical seals on the pump shafts**
 - 2. Refill expansion tank to operating level through make-up demineralizer**
 - 3. Call from AGS Dept. mechanical services call list**

- Notes:**
- 1. Record Actions Taken**
 - 2. MCR = Main Control Room (x 4662)**
 - 3. Call Mech Svcs from "Call In" List**

[Go to Top](#)

Alarm Code **948-6**
Restore **948-7**

Location: **B 928 Basement**

System: **SIEMENS UPS**

- Action:**
- 1. Check status**
 - a) UPS is working on Battery Back-up**
 - b) UPS is working in the Bypass Mode**
 - c) UPS is not working**

 - 2. If UPS is in "A or C", see note 3**

 - 3. If UPS is in "B" proceed as follows:**
 - a) Move rotary switch CCW to position 1, then to position 2.**
 - b) Follow instructions on the display panel.**
 - c) If the UPS cannot be restored to normal operations then see note 3.**
 - d) If the UPS is restored to normal operations then fill out Action Please for information only.**

- Notes:**
- 1. Record Actions Taken**
 - 2. MCR = Main Control Room (x 4662)**
 - 3. Call UPS Tech from "Call In" List**

[Go to Top](#)

Alarm Code **948-8**
Restore **948-9**

Location: **B 928 Basement**

System: **E18 UPS (RING VACUUM)**

- Action:**
- 1. Check status**
 - a) UPS is working on Battery Back-up**
 - b) UPS is working in the Bypass Mode**
 - c) UPS is not working**

 - 2. If UPS is in "A or C", see note 3**

 - 3. If UPS is in "B" proceed as follows:**
 - a) Move rotary switch CCW to position 1, then to position 2.**
 - b) Follow instructions on the display panel.**
 - c) If the UPS cannot be restored to normal operations then see note 3.**
 - d) If the UPS is restored to normal operations then fill out Action Please for information only.**

- Notes:**
- 1. Record Actions Taken**
 - 2. MCR = Main Control Room (x 4662)**
 - 3. Call UPS Tech from "Call In" List**

[Go to Top](#)