

Go To: 949-2 949-4 949-6 949-8 949-F

Alarm Code 949-6
Restore 949-7

Location: B 928/929 RFMG Bldg

System: Building 929 - RF Mezzanine A/C Problems

- Action:**
1. Verify A/C is off or has a problem.
 2. Call Plant Engineering Site Shift Supervisor at x4174, cell – 872-8988 or C/W desk x4284 during off hours.
 3. Advise MCR that RF Cavity and Bldg. A/C will be affected.
 4. Note 1 & 3 the following workday.

- Notes:**
1. Record Actions Taken
 2. MCR = Main Control Room (x 4662)
 3. Call Mech Svcs from "Call In" List

[Back to Top](#)

