REV.	ZONE	ECN NO.	DATE	BY	CKR	APP.

B. Venegas, BNL 8/5/2008 9:46 AM d36-e1126_4.dwg



F/O TX
F/O RX — F/O TX OR RX CARD
94028164 (TX)
94028097 (RX)

CONNECTOR

F/O TX/RX — ETHERNET TRANSCEIVER

SPLICE — FUSION SPLICE

F/O TX / F/O RX — MATH ASSOC. TX OR RX

NOTE: F/O TX FOR TIMING LINKS ARE LOCATED IN 911-B MEZZANINE. F/O JUMPER TO HUB ROOM IS REQUIRED.

INTERBUILDING CABLE IS A 24 FIBER LOOSE TUBE ARMORED CABLE, EXCEPT 911-B TO E-10 WHICH IS A 12 FIBER CABLE.

ALL CABLES ARE 62.5/125 FIBER.

NOTE: BLUE BUFFER, BROWN FIBER IS NO GOOD, BROKEN IN F-10.

-3	-2	-1	REF DESIGNATOR	ITEM NO.	DESCRIPTION	MAT'L DWG NO./BNL NO.
QTY REQD						

INTERPRET IN GENERAL ACCORDANCE WITH ASME Y14.24M-1989
UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES
DECIMAL TOLERANCES .X ±.030 .XX ±.015 .XXX ±.005
ANGULAR TOLERANCE ± .5°
OUTSTANDING ECN
NA FINISH
BREAK SHARP EDGES MAX. XX MIN. XX

Q.A. CATEGORY A-3
DRAWN BY Ed Koropsak 9/4/03
CHECKED BY NOBODY
DESIGN APPROVAL
ENGINEER APPROVAL NONE
SUPVR. APPROVAL
NEXT ASSEMBLY

BROOKHAVEN NATIONAL LABORATORY
UPTON, N.Y. 11973
AGS CONTROLS
FIBER OPTIC PATHS
E10 LINE
SIZE D
DRAWING NUMBER D36-E1126
REV. A
MATERIAL: ——— SCALE: FULL WEIGHT: – SHEET 4 OF 8

*AUTOCAD